



Village of Los Lunas

660 Main Street NW ~ PO Box 1209 ~ Los Lunas ~ NM ~ 87031
Phone 505.839.3840 ~ Fax 505.352.3580 ~ www.loslunasnm.gov

Small Community. Big Possibilities

2017 Consumer Confidence Report

IS MY DRINKING WATER SAFE?

We are pleased to present the 2017 Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by the New Mexico Environment Department/Drinking Water Bureau (NMED/DWB). This is a comprehensive report of last year's water quality for the Village of Los Lunas Water System PWSS# NM3525332.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers and/or EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants. More information is available from the Safe Drinking Water Hotline (800-426-4791). Your health is important to us, please contact a physician with any health concerns.

WHERE DOES MY WATER COME FROM?

The Village of Los Lunas is supplied by ground water pumped from the Santa Fe Group aquifer in the Albuquerque Basin by four wells located within the Village of Los Lunas.

The Water/Sewer Division of the Village of Los Lunas is here to provide excellence in quality and service to customers at a minimal cost while protecting the environment and exceeding all quality standards. The Village operates and maintains a water system consisting of four pressure zones, six steel water storage tanks, four wells, four arsenic treatment plants (one per well), one booster station, 130 miles of water lines and approximately 1053 fire hydrants. The sewer system consists of 23 lift stations, 1910 manholes, and approximately 100 miles of sewer mains. Daily and weekly operations within the Division include: administration, 24 hour on call emergency response, maintenance and inspection of water/sewer utility distribution and collection systems and water treatment facilities, laboratory sampling, fiscal reports, video inspection of sewer mains, and customer service calls as requested.

We Care

We are committed to providing the Village of Los Lunas information to make you aware that the levels of contaminants in your drinking water do not pose a health risk.

This report shows the types and amounts of key elements in your water supply, their likely sources and the maximum contaminant level (MCL) that the EPA considers safe.

Our water system meets the requirements of the Safe Drinking Water Act (SDWA). If for any reason the standards are not met, the public will be notified.

The Village of Los Lunas welcomes your input. Contact the Public Works office for more information on getting involved.

ESPAÑOL

Este reporte contiene información muy importante sobre la calidad de su agua potable durante el año civil 2017. Si usted no comprende esta información, comuníquese con alguien que pueda traducir el información.

WHY ARE THERE CONTAMINANTS IN MY DRINKING WATER?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material. It can also pick up substances resulting from the presence of animals or from human activity (microbial contaminants such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife).

A variety of sources such as agriculture, urban stormwater runoff, and residential uses may contain Inorganic Contaminants such as salts and metals, which can be either naturally occurring or result from urban stormwater runoff, industrial, domestic wastewater discharges, oil and gas production, mining, farming, pesticides and herbicides.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive contaminants can either occur naturally or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

WATER TABLE QUALITY

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table on the right lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report.

SOURCE WATER ASSESSMENT & ITS AVAILABILITY

A Source Water Assessment has been performed for the Village of Los Lunas Water System and is available for review. For a copy of the assessment, Contact David Torres 505.841.5306 or david.torres@state.nm.us.

Although throughout the United States it is common to find potential sources of contamination located atop wellheads, continued regulatory oversight, wellhead protection plans and other planning efforts continue to be the primary methods of protecting

HOW CAN I GET INVOLVED?

The Mayor and Village Council encourage public interest and participation in the community's decisions affecting drinking water. Regular Village Council meetings occur every two weeks on Thursdays at 6 pm at the Village Administration Building. The public is welcome.

All meetings are advertised in the Valencia County New bulletin and on the village website at www.loslunasnm.gov. The Village of Los Lunas Council and staff encourage customers to continue water conservation efforts and implement additional efforts if at all possible.

REGULATED CONTAMINANTS

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	2017	7.9	2.7 - 7.9	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAA5)*	2017	1	1 - 3.9	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
*The highest Locational Running Annual Average (LRAA) occurred in the 4th quarter 2017 with HAA5 reporting at 1.92 ppb. The running annual average for HAA5 reporting is 0.7 ppb								
Total Trihalomethanes (TTHM)*	2017	5.6	0 - 5.6	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
*The highest Locational Running Annual Average (LRAA) occurred in the 4th quarter of 2017 with the TTHM reporting at 3.25 ppb. The running annual average for TTHM reporting is 2.1 ppb. Per our data the highest LRAA was 4.								
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic*	2017	20	6 - 20	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
*While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.								
Chromium	2017	4	0 - 4	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2017	1.03	0.84 - 1.03	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	2017	0.32	0 - 0.32	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	2017	0.04	0 - 0.04	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	2017	5.4	0 - 5.4	0	15	pCi/L	N	Erosion of natural deposits.
Uranium	2017	7	5 - 7	0	30	ug/l	N	Erosion of natural deposits.

Lead & Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2015	1.3	1.3	0.55	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2015	0	15	5	1	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

VIOLATIONS

Violation Type	Violation Begin	Violation End	Violation Explanation
Monitoring, Routine (RTCR), Minor	04/01/2017	04/30/2017	We are required to take 15 routine samples for Total Coliform/E.Coli per month. We took 14 samples; because of this a violation was issued. Results of the 14 samples came back negative for both. We are confident the water was safe during that time frame. Going forward we will check all sampling schedules to ensure proper amounts have been collected.

Unit Descriptions	
Term	Definition
ug/L	ug/L : Number of micrograms of substance in one liter of water
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

INFORMATION FOR LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Los Lunas is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the

potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

INFORMATION FOR ARSENIC

Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system and may have an increased risk of getting cancer.